



TEST CERTIFICATE

PRODUCT "Puerta Acorazada Segurestil Modelo Milenium 3B / 4B"
Armoured door

COMPANY: SEGURESTIL, S.L.
D. MANUEL CORTÉS MAYA
POL. IND. GUADALHORCE
CRTA. AZUCARERA-INTELHORCE, 138
29004 MÁLAGA
B-29077948

TEST Formaldehyde emission according to the standard EN 717-2:1994
Wood-based panels - Determination of formaldehyde release. Part
2: Formaldehyde release by the gas analysis method.

RESULT According to the report (ref. no. 0902014-01) (issued on
5th February 2009), the sample taken from the mentioned door has
obtained the following results:

TEST	TEST METHOD	MEDIUM VALUE	STANDARD DESVIATION
Formaldehyde emission mg HCOH/h.m ²	EN 717-2	4,1	0,3
Formaldehyde classification*	EN 13986	E2	

*Classification according to EN 13986:06

class E1: Emission $\leq 3,5$ mg/m²h
class E2: Emission $> 3,5$ mg/m²h ≤ 8 mg/m²h

Paterna, 05th February 2009



Rosa Mª Pérez Campos, PhD
Head of Materials Laboratory
AIDIMA

This certificate does only apply to the samples tested at the AIDIMA laboratory.