

**TEST CERTIFICATE****PRODUCT**

**“Puerta Acorazada Segurestil.
Modelo Milenium 3B EXTERIOR”**
Armoured door

COMPANY:

SEGURESTIL, S.L.
D. MANUEL CORTÉS MAYA
POL. IND. GUADALHORCE
CRTA. AZUCARERA-INTELHORCE, 138
29004 MÁLAGA
B-29077948

TEST

Formaldehyde emission according to the standard EN 717-2:1994
Wood-based panels - Determination of formaldehyde release. Part
2: Formaldehyde release by the gas analysis method.

RESULT

According to the report (ref. no. 0902014-02) (issued on
5th February 2009), the sample taken from the mentioned door has
obtained the following results:

TEST	TEST METHOD	MEDIUM VALUE	STANDARD DESVIATION
Formaldehyde emission mg HCOH/h.m ²	EN 717-2	4,4	0,1
Formaldehyde classification*	EN 13986	E2	

*Classification according to EN 13986:06

class E1: Emission $\leq 3,5 \text{ mg/m}^2\text{h}$
class E2: Emission $> 3,5 \text{ mg/m}^2\text{h} \leq 8 \text{ mg/m}^2\text{h}$

Paterna, 05th February 2009



Rosa Mª Pérez Campos, PhD
Head of Materials Laboratory
AIDIMA

This certificate does only apply to the samples tested at the AIDIMA laboratory.

"AIDIMA is a member of INNOVAWOOD, the European network of Forestry, Wood and Furniture Research and Training, an organisation that includes, among other, CATAS (Italy), CTBA (France), CTIB (Belgium), DTI (Denmark), ELKEDE (Greece), HFA (Austria), IHD (Germany), ITD (Poland), SHR (Holland), ST-TRÅTEK (Sweden), TRADA-UK (Great Britain), University of Zagreb (Croatia), VTT (Finland), and WKI (Germany), etc"